

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-1591:181 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243  
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

**DESIGN:** Models "EST" 757-3A-RS25, -RS70, 757-7A-RS25, -RS70, 757-8A-RS25, -RS70; "Mirtone" INT-7AR; and "Edwards" 2471-25-15/75-R, -30-R, -110-R, 2471-70-15/75-R, -30-R and -110-R speaker/strobes. Unit may be followed by A through Z to indicate product color. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Candela: -3A, -30: 30cd  
-7A, -15/75, -7AR: 15/75cd  
-8A, -110: 110cd  
  
Electrical: 25 and 70 Vrms

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, candela/electrical rating and UL label.

**APPROVAL:** Listed as speaker/strobes for use with separately listed compatible control units. Suitable for the hearing impaired and for indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** Formerly 7125-1388:205

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**